



# CD/11 Oil Firing Servicing and Commissioning Report

Cert No. 75

Billy Gentleman Heating services Ltd

OFTEC REGISTERED TECHNICIAN'S FORM

### Company / Installer

Engineer Billy Gentleman  
 Company Billy Gentleman Heating services Ltd  
 Address Knana Lodge  
 34 Kilmuir  
 Dunvegan  
 Isle Of Skye  
 Post Code IV55 8GT  
 Tel No. 07739612867  
 Comp OFTEC Reg No. 501696  
 Tech OFTEC Reg No. 15609

### Job Address

Name holiday let  
 Address keepers cottage  
 Post Code  
 Tel. No

### Client / LandLord

Name  
 Company Dunvegan Castle Cottages  
 Address Dunvegan House  
 Lochside  
 Dunvegan  
 Isle Of Skye  
 Post Code IV55 8WF  
 Tel. No

### Pre-commissioning checks

1. Is there a completed CD/10 (or equivalent) for the installation works? No  
 2. If the Installer is not a Competent Person, is there a Building Notice? NA If Yes, insert Ref. No.

Appliance Make Worcester Greenstar Appliance Model Heatslave 32 Serial No.  
 Burner Make Riello RDB Burner Model Burner Type PJ  
 Tank Type Plastic - Bunded Flue Type BF-LLD Fuel Type C2

### Call Type (Tick as appropriate)

Service  Commission  Breakdown  Manufacturer's Warranty  Return Visit

### Oil firing service and Commissioning Schedule

|                                   | Tick if passed                      | Parts fitted / Observations                                |
|-----------------------------------|-------------------------------------|--|
| 1 Oil Storage                     | <input checked="" type="checkbox"/> |  |
| 2 Oil supply system               | <input checked="" type="checkbox"/> | 10mm copper fire valve fitted                              |
| 3 Air supply                      | <input checked="" type="checkbox"/> |  |
| 4 Chimney/flue                    | <input checked="" type="checkbox"/> |  |
| 5 Electrical safety               | <input checked="" type="checkbox"/> |  |
| 6 Heat exchanger                  | <input checked="" type="checkbox"/> |  |
| 7 Combustion chamber              | <input checked="" type="checkbox"/> | removed baffles and cleaned                                |
| 8 Pressure jet burner             | <input checked="" type="checkbox"/> | Stripped burner and cleaned all components replaced nozzle |
| 9 Vaporising and wallflame burner | <input type="checkbox"/>            | N/A  |
| 10 Wallflame burner (additional)  | <input type="checkbox"/>            | N/A  |
| 11 Appliance safety controls      | <input checked="" type="checkbox"/> |  |
| <b>Heating systems service</b>    |                                     |  |
| 12 Controls check                 | <input checked="" type="checkbox"/> |  |
| 13 System check - Hot water type  | <input type="checkbox"/>            |  |
| 14 System check - Warm air type   | <input type="checkbox"/>            |  |

### Important Comments

The comments may include advice on remedial work necessary to enable the installation to comply with the requirements of the Building Regulations, Control of Pollution and British Standards.

Empty box for important comments.

### Test Results

It is important to keep a record of the combustion analysis results - if they have been carried out electronically a copy Print out attached?   
 of the printout should be attached to all copies of the service schedule and report.

|                |        |                     |        |                     |        |
|----------------|--------|---------------------|--------|---------------------|--------|
| Pump Pressure  | 9 psi  | Efficiency Nett     | 99.1 % | Efficiency Gross    |        |
| Pump Vacuum    |        | Smoke No.           | 0      | CO                  | 12 ppm |
| Draught        |        | Nozzle(size)        | 0.85   | Nozzle(angle)       | 80     |
| CO2            | 11.5 % | Flow Rate(oil) Low  |        | Nozzle(pattern)     | EH     |
| Flue Gas Temp. |        | Flow Rate(DHW) Cold |        | Flow Rate(oil) High |        |
|                |        | Flow Rate(DHW) Hot  |        |                     |        |

### I acknowledge receipt of this service and commissioning report.

Issued by: Signed Received by: Signed \_\_\_\_\_ Date 10-Jan-2024  
 Print Name: Billy Gentleman Print Name: \_\_\_\_\_ Recipient's Status \_\_\_\_\_